

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Lift Station Automatic Transfer Switch

DATE OF MEETING: February 14, 2017

BUDGET IMPACT: \$18,850.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Bevel Creek Lift Station Automatic Transfer Switch

HISTORY, FACTS, AND ISSUES: The Automatic Transfer Switch (ATS) at Bevel Creek lift station is not working. Due to hydrogen sulfide gas exposure, the ATS has deteriorated to the extent that it is no longer feasible to repair. The Bevel Creek lift station is the primary lift station before the LAS. Staff has deemed this to be an emergency situation and has received a single bid from Cowart Electric for 18,850.00, to purchase and replace the existing ATS. Staff recommends a new ATS be purchased and installed for \$18,850.00, from Cowart Electric.


- OPTIONS: 1. Approve ATS Purchase
2. Board's Pleasure

RECOMMENDED ACTION: Approve ATS purchase for \$18,850.00

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____