

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Peterson Road Lift Station Isolation Valves

DATE OF MEETING: March 14, 2017

BUDGET IMPACT: \$14,050.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Peterson Road Lift Station Isolation Valves

HISTORY, FACTS, AND ISSUES: The isolation valves at Peterson Road lift station will not close and are deteriorated to the extent that it is no longer feasible to repair. James Warren & Associates has submitted a change order for \$14,050.00, to bypass the flow, remove and replace the two existing isolation valves. Staff recommends the change order be approved and authorize the Chairman to sign.

- OPTIONS: 1. Approve the change order and authorize Chairman to sign.
2. Board's Pleasure

RECOMMENDED ACTION: Approve the change order and authorize Chairman to sign.

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____