

LOWNDES COUNTYBOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Lift Station Pump

DATE OF MEETING: March 28, 2017

BUDGET IMPACT: \$34,908.11

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Bevel Creek Lift Station Pump

---

HISTORY, FACTS, AND ISSUES: The Bevel Creek lift station is a triplex lift station on the county's main trunk line that delivers over 60% of the county's wastewater flow to the LAS. This station is currently running on two pumps. The pump that is out of service is a 27 year old Flygt pump. The price to repair this pump exceeds the cost of a new pump. Quotes are listed below for a new replacement pump. Staff recommends purchasing a new pump from Xylem for \$34,908.11.

Xylem	\$34,908.11
GWI	\$35,842.10
AAG	\$38,930.50

- OPTIONS: 1. Approve Pump Purchase  
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase from the low bidder in the amount of \$34,908.11.


DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

---

---

  
County Manager

Action Taken By Board: \_\_\_\_\_