

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Spring Creek Well Pump

DATE OF MEETING: July 11, 2017

BUDGET IMPACT: \$27,750.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting
Work Session
Recommendation
Policy/Discussion
Report
Other

COUNTY ACTION REQUESTED ON: Spring Creek Well Pump

HISTORY, FACTS, AND ISSUES: The Spring Creek water system is served by one well at 4245 Hattie Place. Due to reduced output, the well has been running 24 hours per day to keep up with demand. After initial troubleshooting, Shea Well & Pump pulled the pump and determined a new pump & motor will have to be installed to achieve the required output. The cost of a new pump, motor, and installation is \$27,750.00. Due to the emergency situation, staff recommends the Board of Commissioners approve the purchase of a new pump, motor, and installation for \$27,750.00 from Shea Well & Pump.


- OPTIONS: 1. Approve Purchase of Well Pump.
2. Board's pleasure.

RECOMMENDED ACTION: Approve Purchase of Well Pump & Motor from Shea Well & Pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____