

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Francis Lake Lift Station Repair

DATE OF MEETING: June 26, 2018

BUDGET IMPACT: \$19,594.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Francis Lake Lift Station Repair

HISTORY, FACTS, AND ISSUES: The Francis Lake lift station is a triplex lift station that delivers all of our wastewater flow from the Lake Park area, to the LAS. During routine maintenance, the pumps were found to be pumping below the recommended capacity. After further inspection, it was determined that the impellers and wear rings are in need of replacement. Lowndes County received two quotes for the impellers and wear rings:

- Goforth and Williams \$19,594.00
- Xylem, Inc. \$20,181.00

Staff recommends parts be purchased from Goforth and Williams for \$19,594.00

- OPTIONS: 1. Approve Purchase for \$19,594.00
2. Board's Pleasure

RECOMMENDED ACTION: Approve Purchase for \$19,594.00

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____