

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Coleman Road Lift Station Check Valves

DATE OF MEETING: August 14, 2018

BUDGET IMPACT: \$11,179.20

FUNDING SOURCE

- Annual SPLOST VII
- Capital
- N/A

- Regular Meeting (X)
- Work Session (X)
- Recommendation ()
- Policy/Discussion ()
- Report ()
- Other ()

COUNTY ACTION REQUESTED ON: Coleman Road Lift Station Check Valves

The 16" force main between Coleman Road lift station and James Road has experienced repeated issues with pressure and water hammer. This has caused pipe failure in some instances. After additional troubleshooting and consultation, it has been determined that changing the check valves should improve the water hammer issues. Staff recommends two 12" Surgebuster check valves be purchased for \$11,179.20, from Temsco, Inc.

- OPTIONS: 1. Approve check valve replacement from Temsco, Inc.
2. Board's Pleasure

RECOMMENDED ACTION: Approve check valve purchase for \$11,179.20, from Temsco, Inc.

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:



County Manager

Action Taken By Board: _____