

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Gorman Rupp Bypass Pump Retrofit

DATE OF MEETING: August 14, 2018

BUDGET IMPACT: \$12,883.95

FUNDING SOURCE

- (x) Annual () SPLOST VII
() Capital
() N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Gorman Rupp Bypass Pump Retrofit

The Gorman Rupp Bypass pump is currently inoperable. The motor runs fine, the pump has had issues for several years. Staff has researched several options and determined the best option would be to retro fit our Gorman Rupp unit with a 4" Godwin Dri-Prime CD 100M pump end. We received a quote to install a 4" Godwin Dri-Prime CD 100M pump end on our Gorman Rupp unit for \$12,883.95. A new 4" Godwin bypass pump costs \$34,296.00.

- OPTIONS: 1. Approve pump retrofit.
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump retrofit for \$12,883.95.

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____