

LOWNDES COUNTYBOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Hart Road/Skipper Bridge Lift Station Pumps

DATE OF MEETING: August 14, 2018

BUDGET IMPACT: \$31,962.93

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Hart Road/Skipper Bridge Lift Station Pumps

HISTORY, FACTS, AND ISSUES: The Hart Road lift station is a duplex lift station on our main trunk. This station is currently running on one pump. We have a quote from Xylem, Inc. to repair the pump that is out of service for \$15,289.00. Additional, we have a quote on a new pump for \$31,231.20. Staff recommends the pump be repaired for \$15,289.00.

The Skipper Bridge lift station is a duplex station that serves the Bemiss area. This station is currently running on one pump. The pump out of service is a 23 horsepower Flygt pump. We have a quote from Xylem, Inc. to repair this pump for \$12,303.96. Additionally, we have a quote for a new replacement pump from Xylem Inc. for \$16,673.93. Staff recommends purchasing a new pump for \$16,673.93.

- OPTIONS: 1. Approve pump repair & replacement.  
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump repair & replacement from Xylem, Inc. for \$31,962.93.


DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

---

---

  
County Manager

Action Taken By Board: \_\_\_\_\_