

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Val-Tech Road 16" Force Main Emergency Repair

DATE OF MEETING: October 9, 2018

BUDGET IMPACT: \$99,935.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Val-Tech Road 16" Force Main Emergency Repair

The 16" force main between Coleman Road lift station and James Road has experienced repeated issues with pipe failure. Several repairs have been made on one section near 3624 Val-Tech Road. After detecting another pipe failure along this section staff recommends we replace a 400' section of the 16" force main. This is an emergency and needs to happen ASAP to prevent a sewage spill. Staff received a quote from RPI for \$99,935.00. Staff recommends the emergency repair be approved for \$99,935.00 from RPI.


- OPTIONS: 1. Approve 16" force main emergency repair for \$99,935.00 from RPI.
2. Board's Pleasure

RECOMMENDED ACTION: Approve 16" force main emergency repair for \$99,935.00 from RPI.

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____