

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Hart Road Lift Station Pump

Work Session/Regular Session

DATE OF MEETING: November 12, 2019

BUDGET IMPACT: \$30,589.30

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: the purchase of a new pump for Xylem, Inc. for \$30,589.30

HISTORY, FACTS AND ISSUES: The Hart Road pump station is on the main trunk line. Pump #2 was sent in for repairs due to a high amp reading. Due to the condition of the pump, repairs exceed 75% of the cost of a new pump. Staff recommends a new pump be purchased from Xylem, Inc. for \$30,589.30.

OPTIONS: 1. Approve the Purchase of a new pump from Xylem In. for \$30,589.30

2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: