

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Francis Lake Lift Station Pump

Work Session/Regular Session

DATE OF MEETING: December 10, 2019

BUDGET IMPACT: \$31,426.80

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Approval of repair of pump

HISTORY, FACTS AND ISSUES: Pump #1 at the Francis Lake lift station was pumping below capacity. This is a 75Hp pump. Upon inspection it was determined that the pump requires a complete rebuild. A quote was received from Xylem, Inc. for \$31,426.80. Staff recommends the pump be repaired by Xylem, Inc. for \$31,426.80.

OPTIONS: Approval
Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: