

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Blue Lake Lift Station Emergency Repair

Work Session/Regular Session

DATE OF MEETING: June 9, 2020

BUDGET IMPACT: \$71,789.00

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Blue Lake Lift Station Emergency Repair

HISTORY, FACTS AND ISSUES: The discharge pipes at Blue Lake lift station are leaking due to corrosion. Staff has deemed this an emergency due to the condition of the pipes and the pumps not operating at capacity. A bid was received from RPI Underground Inc. for \$71,789.00 to make the necessary repairs to bring the station back to designed capacity and operation. Staff recommends approval of Blue Lake lift station emergency repairs and authorize RPI Underground Inc to make the repairs for \$71,789.00.

- OPTIONS: 1. Approve Blue Lake lift station emergency repairs and authorize RPI Underground Inc to make the repairs for \$71,789.00.
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: