

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Moody Water Treatment Plant Emergency Repair

Work Session/Regular Session

DATE OF MEETING: January 12, 2021

BUDGET IMPACT: \$2,500.00

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Moody Water Treatment Plant Emergency Repair

HISTORY, FACTS AND ISSUES: The header piping leading into the cartridge filters is leaking in four places. Due to the design the entire header will have to be replaced. After consultation with Moody and Lanier Municipal it was determined that replacing this section with HDPE piping would be the best solution. RPI, Inc. submitted a price not to exceed \$25,000.00, to supply the parts and the work was performed during the week of December 28th, 2020. This is a reimbursable item on the contract, Lowndes County is responsible for \$2,500.00, with Moody reimbursing the balance. Staff recommends approval.

- OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: