

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Val-Tech Lift Station Pump

DATE OF MEETING: October 27, 2015

BUDGET IMPACT: \$20,076.42

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Val-Tech Lift Station Pump

HISTORY, FACTS, AND ISSUES: The Val-Tech lift station is a duplex station that delivers wastewater to the Coleman Road station. Currently, only one pump is in service at the Val-Tech station. The cost to repair the pump that is out of service is \$18,219.00. A new pump can be purchased for \$20,076.42. With the cost to repair being over the standard 66% of the cost of a new pump, staff recommends that the Board of Commissioners approve the purchase of a new pump in the amount of \$20,076.42, to be paid from the annual budget.


- OPTIONS: 1. Approve Purchase of Flygt Pump
2. Board's Pleasure

RECOMMENDED ACTION: 1. Approve Purchase of Flygt Pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____