

LOWNDES COUNTY BOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Whitewater Lift Station Pump

DATE OF MEETING: October 27, 2015

BUDGET IMPACT: \$13,353.65

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Whitewater Lift Station Pump

---

HISTORY, FACTS, AND ISSUES: The Whitewater lift station is a triplex station that transfers wastewater to the Bevel Creek station. Currently, there are only two pumps running at the Whitewater station. The cost to repair the pump that is out of service is \$13,353.65. A new pump can be purchased for \$24,003.94. Staff recommends that the Board of Commissioners approve the repairs in the amount of \$13,353.65, to be paid from the annual budget.

- OPTIONS: 1. Approve Repairs for the Flygt Pump  
2. Board's Pleasure

RECOMMENDED ACTION: 1. Approve Repairs for the Flygt Pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

---

---

  
County Manager

Action Taken By Board: \_\_\_\_\_