

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Stone Creek Primary Well Pump

DATE OF MEETING: April 26, 2016

BUDGET IMPACT:
FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Stone Creek Primary Well Pump

HISTORY, FACTS, AND ISSUES: The Stone Creek primary well pump provides water to the North Lowndes System. Due to reduced output, the well will not supply enough flow to operate the MIEX plant at Stone Creek. After initial troubleshooting, Shea Well & Pump pulled the pump and determined a new pump will have to be installed to achieve the required output. The cost of a new pump and installation is \$27,985.00. Due to the emergency situation, staff recommends the Board of Commissioners approve the purchase of a new pump & installation for \$27,985.00, from Shea Well & Pump, to be paid from the capital budget.


- OPTIONS: 1. Approve Purchase of Well Pump from Shea Well & Pump
2. Board's Pleasure

RECOMMENDED ACTION: Approve Purchase of Well Pump from Shea Well & Pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____