

LOWNDES COUNTY BOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Kinderlou Lift Station Pump

DATE OF MEETING: May 24, 2016

BUDGET IMPACT: \$10,379.00

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Kinderlou Lift Station Pump

---

HISTORY, FACTS, AND ISSUES: Kinderlou lift station is a duplex station that is currently running on one pump. The pump that is out of service is a 10 horsepower Flygt pump, purchased in 2000. We have a quote from Xylem Inc. to repair this pump for \$9,522.50. Additionally we have a quote for a new replacement pump, from Xylem Inc. for \$10,379.00. Staff recommends a new pump be purchased for \$10,379.00.

- OPTIONS: 1. Approve Pump Purchase  
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase for \$10,379.00, from Xylem Inc.


DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

---

---

  
County Manager

Action Taken By Board: \_\_\_\_\_