

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Foxborough Pressure Reducing Valve

DATE OF MEETING: July 28, 2016

BUDGET IMPACT: \$8,987.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Foxborough Pressure Reducing Valve

HISTORY, FACTS, AND ISSUES: Foxborough Subdivision has three lines that loop and supply water to the subdivision. Two of these lines have PRVs and the third does not. Since the new booster pump came online and increased usage during the summer months, we have had complaints about high pressure in the Foxborough area. Staff received three quotes listed below to install a vault and PRV on the third line to alleviate the high pressure issues. Staff recommends Standard Contractors install the vault and PRV for \$8,987.00.

Standard Contractors	\$8,987.00
Killeen Construction	\$10,500.00
Radney Plumbing	\$13,436.00

- OPTIONS: 1. Approve Standard Contractors to install the vault and PRV for \$8,987.00.
2. Board's Pleasure

RECOMMENDED ACTION: Approve PRV & Vault Installation by Standard Contractors for \$8,987.00.

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____