

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Blue Lake Lift Station Pump

DATE OF MEETING: September 27, 2016

BUDGET IMPACT: \$34,959.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Blue Lake Lift Station Pump

HISTORY, FACTS, AND ISSUES: The Blue Lake lift station is a duplex lift station on our main trunk line. This station is currently running on one pump. The pump that is out of service is a 60 horsepower Flygt pump. Xylem Inc. can repair this pump for \$25,474.09 with a one year warranty or provide a new replacement pump for \$34,959.00 with a five year warranty. This pump has not been bid due to it being a sole source item in accordance with the County's standards and specifications. This has been verified by the County's purchasing agent. Staff recommends a new pump be purchased for \$34,959.00.


- OPTIONS: 1. Approve Pump Purchase
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase for \$34,959.00

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____