

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Pine Grove Middle School Lift Station Pump

DATE OF MEETING: September 27, 2016

BUDGET IMPACT: \$13,054.00

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Pine Grove Middle School Lift Station Pump

HISTORY, FACTS, AND ISSUES: The Pine Grove Middle School lift station is a duplex station that serves both Pine Grove Middle and Pine Grove Elementary Schools. This station is currently running on one pump. The pump that is out of service is a 23 horsepower Flygt pump. Xylem Inc. can repair this pump for \$11,198.00 with a one year warranty or provide a new replacement pump for \$13,054.00 with a five year warranty. This pump has not been bid due to it being a sole source item in accordance with the County's standards and specifications. This has been verified by the County's purchasing agent. Staff recommends a new pump be purchased for \$13,054.00.

- OPTIONS: 1. Approve Pump Purchase
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase for \$13,054.00

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____