

LOWNDES COUNTY BOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Moody Housing Lift Station Pump

DATE OF MEETING: September 27, 2016

BUDGET IMPACT: \$12,136.00

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Moody Housing Lift Station Pump

---

HISTORY, FACTS, AND ISSUES: The Moody Housing lift station is a duplex station that serves the Magnolia Grove Housing area at Moody AFB. This station is currently running on one pump. The pump that is out of service is a 23 horsepower Flygt pump. Xylem Inc. can repair this pump for \$11,935.00 with a one year warranty or provide a new replacement pump for \$12,136.00 with a five year warranty. This pump has not been bid due to it being a sole source item in accordance with the County's standards and specifications. This has been verified by the County's purchasing agent. Staff recommends a new pump be purchased for \$12,136.00.

- OPTIONS: 1. Approve Pump Purchase  
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase for \$12,136.00


DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

---

---

  
County Manager

Action Taken By Board: \_\_\_\_\_